

April 25, 2007

VAN GOETHEM SEPTIC SYSTEMS, INC.
CONCRETE DEPT.
LONNY VAN GOETHEM
EAST 3055 COUNTY HWY J
KEWAUNEE WI 54216

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: VAN GOETHEM SEPTIC SYSTEMS, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 1000
(36.5" L.L., 27.6 GAL/IN., 42" MAX. DEPTH OF BURY, 482 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20070069

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This approval supersedes the approval issued on November 3, 2000, under product file number 20002149.

This approval is contingent upon compliance with the following stipulation(s):

- **A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.**
- This product is approved to use the following:
 - Opening cast in riser for electrical wiring.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank wall.
 - "Cast-A-Seal" by Press Seal Gasket Corp.
 - Polypropylene riser and access cover by EZ Set Tank Company
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742, fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov